

BOARD OF HEALTH
MINUTES
April 13, 2016

This meeting was advertised in the Hunterdon County Democrat, and notice posted in the Alexandria Township Municipal Office and the Alexandria Township website (www.alexandrianj.gov) as required by the Open Public Meetings Act.

Meeting called to Order at 7:33 PM.

ROLL CALL:

Present: Committeewoman Garay, Mayor Pfefferle, Chair Abraham , Attorney Dragan
Absent: None

ITEMS FOR DISCUSSION:

- Wickel -202 Route 579
Solid Waste Complaint

Township Clerk Bobrowski will follow up with Hunterdon County Health Inspector Mario Filippi as to an update to the violation.

- Well Issues
B-14, L-23
403 County Road 513

Kurt Hoffman, PE was present for the above property. Two waivers need to be approved by the Alexandria Township Board of Health as noted in correspondence from the Hunterdon County Health Department dated April 1, 2016. Comm. Garay made a motion, seconded by Mayor Pfefferle to approve the following waivers:

1. The new well will be only 79 feet from the newly installed septic field which does not meet the minimum 100 foot setback requirement by code. As per 7:9A-4.3, the distance can be reduced to 50 feet provided there is 50 feet of casing in the well. The well does have 80 feet of casing, therefore the Board can consider the waiver request.
2. The well was installed in the driveway in a well monitoring pit, which according to the well code requires approval from the Administrative Authority. The well driller has provided a detail of the pit showing the heavy duty well cover for traffic, concrete base, water tight seal and vent. The driller shall explain to the Board how this vault and cover is water tight and a sump pump would not be needed. This department will also inspect the monitoring port when installed.

Roll Call: Aye: Garay, Abraham, Pfefferle
Nay: None

Motion Carried

APPROVAL OF MINUTES:

- March 9, 2016, 2016-Board of Health Meeting
Comm. Garay made a motion, seconded by Chair Abraham to approve the meeting minutes of March 9, 2016.

Roll Call: Aye: Garay, Abraham, Pfefferle
Nay: None

Motion Carried

CORRESPONDENCE / ANNOUNCEMENTS:

- The Community Well Test Day is scheduled for Saturday, April 23, 2016 at the Municipal Offices from 9 AM to 12 Noon. The basic kit is \$60.00. Additional testing is available for an additional cost. Additional information can be found at www.alexandrianj.gov.

COMMENTS FROM THE FLOOR:

MOTION TO ADJOURN:

Comm. Garay made a motion, seconded by Mayor Pfefferle to adjourn.

Roll Call: Aye: Garay, Abraham, Pfefferle
Nay: None

Motion Carried

Meeting Adjourned at 7:41 PM.

Respectfully Submitted,

Michele Bobrowski
Board of Health Secretary

